




Date: May 16, 2023

CERTIFICATE OF COMPLIANCE N° COC-126

| This certificate of compliance validates the following | | | |
|----------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------|----------------------------|---------------------------------------------------------------------------------------|
| TEST REPORT NUMBER 'Assessment Reports' are not acceptable | FE200007 | CERTIFICATE NUMBER | 1116-CPR-126 |
| DATE OF ISSUE | 21/09/2020 | DATE OF ISSUE | 22/01/2021 |
| DATE OF EXPIRY | Not Applicable | DATE OF EXPIRY | Not Applicable |
| Manufacturer details | | | |
| NAME OF FACTORY / MANUFACTURER | ZHEJIANG JIABOER ELECTRONIC TECHNOLOGY CO.,LTD | NAME OF THE BRAND | ZHEJIANG JIABOER ELECTRONIC TECHNOLOGY CO.,LTD |
| FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY) | No.72, Dayantou, Tingshan Village , Dayuan Town, Fuyang District Hangzhou City 311413, Zhejiang Province – CHINA | MODEL / NO | TSS380D-HR |
| WEBSITE | www.jbe-lifepro.com | LOGO ON THE PRODUCT |  |
| TEL | +86 571 63501151 | EMAIL | sales@jbe-lifepro.com |





| Product Details From Test Report | | Reference Test Report page NO | | | | | | | | | | | | | | | | | | | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|-------------------|---------|--|----------------------------------|----|--|----------------------------|-----------------------------|-----|-------------------------------------------|----|---------------------------------------|-------------------|-------------------------|-----|--------------------------------------------------------|-----|--|---------|
| DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC) | Smoke alarm device | 1 | | | | | | | | | | | | | | | | | | | | | |
| TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC) | EN 14604:2005 + AC:2008 | 2 | | | | | | | | | | | | | | | | | | | | | |
| TEST DESCRIPTION | Determination of product type on the basis of type tests carried out in accordance with the annex ZA of the European standards EN 14604 (July 2005) and its amendment AC (October 2008) | 2 | | | | | | | | | | | | | | | | | | | | | |
| SPECIFICATION OF TEST SPECIMEN | Origin of the product: Submitted by the manufacturer Options with requirements | 3 and 4 | | | | | | | | | | | | | | | | | | | | | |
| TEST RESULT (SUCH AS PASSED CRITERIA ___/ COMPLIED TO ___/ DURATION ___/OBSERVATION ___/ETC) | <table border="1"> <tr> <td>Normal power source:</td> <td colspan="2">Internal to the device by lithium battery of 3V (10 years) PAIRDEER CR17450G – 2300 mAh GP International CR17450 – 2300 mAh EVE ENERGY CR17450 – 2400 mAh</td> </tr> <tr> <td>Type of mounting:</td> <td colspan="2">Ceiling</td> </tr> <tr> <td>Radio link (other than SAD-SAD):</td> <td colspan="2">No</td> </tr> <tr> <td rowspan="4">Options with requirements:</td> <td>Individual alarm indicator:</td> <td>Yes</td> </tr> <tr> <td>Connection of external ancillary devices:</td> <td>No</td> </tr> <tr> <td>Inter-connectable smoke alarm device:</td> <td>Yes Radio link</td> </tr> <tr> <td>Alarm silence facility:</td> <td>Yes</td> </tr> <tr> <td>Smoke alarm device for leisure accommodation vehicles:</td> <td>Yes</td> <td></td> </tr> </table> | Normal power source: | Internal to the device by lithium battery of 3V (10 years) PAIRDEER CR17450G – 2300 mAh GP International CR17450 – 2300 mAh EVE ENERGY CR17450 – 2400 mAh | | Type of mounting: | Ceiling | | Radio link (other than SAD-SAD): | No | | Options with requirements: | Individual alarm indicator: | Yes | Connection of external ancillary devices: | No | Inter-connectable smoke alarm device: | Yes Radio link | Alarm silence facility: | Yes | Smoke alarm device for leisure accommodation vehicles: | Yes | | 3 and 4 |
| Normal power source: | Internal to the device by lithium battery of 3V (10 years) PAIRDEER CR17450G – 2300 mAh GP International CR17450 – 2300 mAh EVE ENERGY CR17450 – 2400 mAh | | | | | | | | | | | | | | | | | | | | | | |
| Type of mounting: | Ceiling | | | | | | | | | | | | | | | | | | | | | | |
| Radio link (other than SAD-SAD): | No | | | | | | | | | | | | | | | | | | | | | | |
| Options with requirements: | Individual alarm indicator: | Yes | | | | | | | | | | | | | | | | | | | | | |
| | Connection of external ancillary devices: | No | | | | | | | | | | | | | | | | | | | | | |
| | Inter-connectable smoke alarm device: | Yes Radio link | | | | | | | | | | | | | | | | | | | | | |
| | Alarm silence facility: | Yes | | | | | | | | | | | | | | | | | | | | | |
| Smoke alarm device for leisure accommodation vehicles: | Yes | | | | | | | | | | | | | | | | | | | | | | |
| PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN ___/TO BE INSTALLED AT ___/TO BE CONNECTED WITH ___/TO BE INSTALLED WITH ___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN ___/NOT TO BE INSTALLED AT ___/ NOT TO BE INSTALLED WITH ___ ETC. | Smoke alarm devices for domestic applications or similar | According to the Declaration of performance provided by the manufacturer | | | | | | | | | | | | | | | | | | | | | |



| Laboratory and Certification body details | | | |
|----------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------|
| NAME OF CERTIFICATION BODY | CNPP Cert.  | NAME OF TEST FACILITY | CNPP  |
| CERTIFICATION BODY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small> | Route de la Chapelle Réanville 27950 SAINT MARCEL FRANCE | TEST FACILITY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small> | Route de la Chapelle Réanville 27950 SAINT MARCEL FRANCE |
| WEBSITE | www.cnpp.com | WEBSITE | www.cnpp.com |
| TEL | +33 (0)2 32 53 63 63 | TEL | +33 (0)2 32 53 64 49 |
| EMAIL | certification@cnpp.com | EMAIL | lei@cnpp.com |
| ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)</small> | COFRAC www.cnpp.com | ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)</small> | COFRAC www.cnpp.com |
| AS PER <small>(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)</small> | EN ISO/CEI 17065:2012 | AS PER <small>(STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)</small> | EN ISO/CEI 17025:2017 |
| VALIDITY <small>(EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)</small> | 30/04/2025 | VALIDITY <small>(EXPIRY DATE OF LABORATORY ACCREDITATION)</small> | 31/07/2026 |
| REFERENCE NUMBER: <small>(CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small> | 5-0547 | REFERENCE NUMBER: <small>(THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small> | 1-0064 |
| CERTIFICATION MARK | CE MARKING - notified body under N°1116 | | |

| (ENDORSEMENT) TO BE SIGNED BY MANUFACTURER | | | |
|-------------------------------------------------------------------------------------------|--------------------------------------------|------------------------------|---------------------------------------------------------------------------------------|
| NAME OF MANUFACTURER'S SIGNATORY | Li Yuzhe | SIGNATURE |  |
| EMAIL / TEL | sales@jbe-lifeopro.com +86 571 63501151 | FACTORY OFFICIAL SEAL |  |
| NOTES: I Undertake that all data and information provided are genuine and accurate | | | |

| (ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY | | | |
|-------------------------------------------------------------------------------------------|------------------------------------------------|-----------------------------------------|---------------------------------------------------------------------------------------|
| NAME OF CERTIFICATION BODY SIGNATORY | Christophe BODIN | SIGNATURE |  |
| EMAIL / TEL | certification@cnpp.com +33 (0)2 32 53 63 63 | CERTIFICATION BODY OFFICIAL SEAL |  |
| NOTES: I Undertake that all data and information provided are genuine and accurate | | | |

ATTACHMENTS:

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)