




Date: May 16, 2023



CERTIFICATE OF COMPLIANCE N° COC-128

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	FE200046	CERTIFICATE NUMBER	1116-CPR-128
DATE OF ISSUE	20/11/2020	DATE OF ISSUE	22/01/2021
DATE OF EXPIRY	Not Applicable	DATE OF EXPIRY	Not Applicable
Manufacturer details			
NAME OF FACTORY / MANUFACTURER	ZHEJIANG JIABOER ELECTRONIC TECHNOLOGY CO.,LTD	NAME OF THE BRAND	ZHEJIANG JIABOER ELECTRONIC TECHNOLOGY CO.,LTD
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	No.72, Dayantou, Tingshan Village , Dayuan Town, Fuyang District Hangzhou City 311413, Zhejiang Province – CHINA	MODEL / NO	TSS382D-HR
WEBSITE	www.jbe-lifepro.com	LOGO ON THE PRODUCT	
TEL	+86 571 63501151	EMAIL	sales@jbe-lifepro.com





Product Details From Test Report		Reference Test Report page NO																					
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Smoke alarm device	1																					
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 14604:2005 + AC:2008	2																					
TEST DESCRIPTION	Determination of product type on the basis of type tests carried out in accordance with the annex ZA of the European standards EN 14604 (July 2005) and its amendment AC (October 2008)	2																					
SPECIFICATION OF TEST SPECIMEN	Origin of the product: Submitted by the manufacturer Options with requirements	3 and 4																					
TEST RESULT (SUCH AS PASSED CRITERIA ___/ COMPLIED TO ___/ DURATION ___/OBSERVATION ___/ETC)	<table border="1"> <tr> <td>Normal power source:</td> <td colspan="2">Internal to the device by lithium battery of 3V (10 years) PAIRDEER CR17450G – 2300 mAh GP International CR17450 – 2300 mAh EVE ENERGY CR17450 – 2400 mAh</td> </tr> <tr> <td>Type of mounting:</td> <td colspan="2">Ceiling</td> </tr> <tr> <td>Radio link (other than SAD-SAD):</td> <td colspan="2">No</td> </tr> <tr> <td rowspan="4">Options with requirements:</td> <td>Individual alarm indicator:</td> <td>Yes</td> </tr> <tr> <td>Connection of external ancillary devices:</td> <td>No</td> </tr> <tr> <td>Inter-connectable smoke alarm device:</td> <td>Yes Radio link</td> </tr> <tr> <td>Alarm silence facility:</td> <td>Yes</td> </tr> <tr> <td>Smoke alarm device for leisure accommodation vehicles:</td> <td colspan="2">Yes</td> </tr> </table>	Normal power source:	Internal to the device by lithium battery of 3V (10 years) PAIRDEER CR17450G – 2300 mAh GP International CR17450 – 2300 mAh EVE ENERGY CR17450 – 2400 mAh		Type of mounting:	Ceiling		Radio link (other than SAD-SAD):	No		Options with requirements:	Individual alarm indicator:	Yes	Connection of external ancillary devices:	No	Inter-connectable smoke alarm device:	Yes Radio link	Alarm silence facility:	Yes	Smoke alarm device for leisure accommodation vehicles:	Yes		3 and 4
Normal power source:	Internal to the device by lithium battery of 3V (10 years) PAIRDEER CR17450G – 2300 mAh GP International CR17450 – 2300 mAh EVE ENERGY CR17450 – 2400 mAh																						
Type of mounting:	Ceiling																						
Radio link (other than SAD-SAD):	No																						
Options with requirements:	Individual alarm indicator:	Yes																					
	Connection of external ancillary devices:	No																					
	Inter-connectable smoke alarm device:	Yes Radio link																					
	Alarm silence facility:	Yes																					
Smoke alarm device for leisure accommodation vehicles:	Yes																						
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN ___/TO BE INSTALLED AT ___/TO BE CONNECTED WITH ___/TO BE INSTALLED WITH ___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN ___/NOT TO BE INSTALLED AT ___/ NOT TO BE INSTALLED WITH ___ ETC.	Smoke alarm devices for domestic applications or similar	According to the Declaration of performance provided by the manufacturer																					



Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	CNPP Cert. 	NAME OF TEST FACILITY	CNPP 
CERTIFICATION BODY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Route de la Chapelle Réanville 27950 SAINT MARCEL FRANCE	TEST FACILITY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Route de la Chapelle Réanville 27950 SAINT MARCEL FRANCE
WEBSITE	www.cnpp.com	WEBSITE	www.cnpp.com
TEL	+33 (0)2 32 53 63 63	TEL	+33 (0)2 32 53 64 49
EMAIL	certification@cnpp.com	EMAIL	lei@cnpp.com
ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)</small>	COFRAC www.cnpp.com	ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)</small>	COFRAC www.cnpp.com
AS PER <small>(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)</small>	EN ISO/CEI 17065:2012	AS PER <small>(STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)</small>	EN ISO/CEI 17025:2017
VALIDITY <small>(EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)</small>	30/04/2025	VALIDITY <small>(EXPIRY DATE OF LABORATORY ACCREDITATION)</small>	31/07/2026
REFERENCE NUMBER: <small>(CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small>	5-0547	REFERENCE NUMBER: <small>(THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small>	1-0064
CERTIFICATION MARK	CE MARKING - notified body under N°1116		

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Li Yuzhe	SIGNATURE	
EMAIL / TEL	sales@jbe-lifeopro.com +86 571 63501151	FACTORY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	Christophe BODIN	SIGNATURE	
EMAIL / TEL	certification@cnpp.com +33 (0)2 32 53 63 63	CERTIFICATION BODY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)